

PAT Report Passes

For all Sites and Locations

CLIENT DETAILS	
Company Name:	Xanthosia Ltd Trading as foxyswoodfirepizza
Address:	47 West Woodside Bexley Kent DA5 3PQ



DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING	
Company Name:	SGS Electrical Contractors Limited
Address:	The Stables R/O 10 Birkbeck Road Sidcup Kent DA14 4DE
Telephone:	02086161510
Mobile:	
Email:	enquiry@sgselectricalcontractors.co.uk
Cert Number:	
Order Number:	
File Name:	Grahame Fox.PAT
Signature:	

Appliance Details and Test Results										
<div>Key</div> <div>P = PASS / F = FAIL / S = SKIP (or test not applicable)</div>										
Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status	
PIZZA VAN - VAN										
001	ROLLER BACKUP	21/04/17	P	S	S	P >199	S	S	PASS	
002	TILLSPARE	21/04/17	P	S	S	P >199	S	S	PASS	
003	EYEWASH SPARE	21/04/17	P	S	S	P >199	S	S	PASS	
004	INVERTER LEAD	21/04/17	P	S	S	P >199	S	S	PASS	
005	110 EXT LEAD	21/04/17	P	S	S	P >199	S	S	PASS	

Total Appliances > 5

Total Appliances For Report: 5